
Energy performance certificate (EPC)			
326 Stranmillis Road BELFAST BT9 5EB	Energy rating	Valid until:	10 December 2034
RIA 2FR	E	Certificate number:	0434-8922-5409-0729-4296
Property type	S	Semi-detached house	9
Total floor area	127 square metres		

Energy rating and score

This property's energy rating is E. It has the potential to be D.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Roof	Pitched, 50 mm loft insulation	Poor
Roof	Pitched, insulated (assumed)	Average
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, no room thermostat	Very poor
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 86% of fixed outlets	Very good
Floor	Suspended, no insulation (assumed)	N/A
Floor	Suspended, limited insulation (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

Primary energy use

The primary energy use for this property per year is 257 kilowatt hours per square metre (kWh/m2).

How this affects your energy bills

An average household would need to spend £2,100 per year on heating, hot water and lighting in this property. These costs usually make up the majority of your energy bills.

You could save £461 per year if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment

This property's environmental impact rating is F. It has the potential to be E.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household	6 tonnes of CO2
produces	

This property produces8.5 tonnes of CO2This property's potential
production6.5 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Increase loft insulation to 270 mm	£100 - £350	£113
2. Increase hot water cylinder insulation	£15 - £30	£25
3. Heating controls (room thermostat and TRVs)	£350 - £450	£219
4. Floor insulation (suspended floor)	£800 - £1,200	£104
5. Solar water heating	£4,000 - £6,000	£163
6. Internal or external wall insulation	£4,000 - £14,000	£387
7. Solar photovoltaic panels	£3,500 - £5,500	£433

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Dermot McGladery
Telephone	07703 495777
Email	dermotmcgladery@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/005938
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	11 December 2024
Date of certificate	11 December 2024
Type of assessment	RdSAP