Energy performance certificate (EPC)			
12b Rock Lane Aghagallon	Energy rating	Valid until:	9 September 2034
CRAIGAVON BT67 0AX		Certificate number:	2253-1111-1041-9491-8821
Property type Detached house			
Total floor area	228 square metres		

Energy rating and score

This property's energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.

Score	Energy rating		Current	Potential
92+	Α			
81-91	B			
69-80	С		75 C	75 C
55-68	D			
39-54	E			
21-38		F		
1-20		G		

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

the average energy rating is D the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, insulated (assumed)	Good
Roof	Roof room(s), insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, oil	Average
Main heating control	Time and temperature zone control	Very good
Hot water	From main system	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, insulated (assumed)	N/A
Secondary heating	Room heaters, dual fuel (mineral and wood)	N/A

Primary energy use

The primary energy use for this property per year is 106 kilowatt hours per square metre (kWh/m2).

Additional information

Additional information about this property:

Dwelling may be exposed to wind-driven rain

How this affects your energy bills

An average household would need to spend **£1,678 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £0 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2024** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Impact on the environment		This property produces	6.2 tonnes of CO2	
This property's environmer C. It has the potential to be		This property's potential production	0.0 tonnes of CO2	
Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.		You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.		
Carbon emissions		These ratings are based about average occupancy	/ and energy use.	
An average household produces	6 tonnes of CO2	People living at the property may use diff amounts of energy.		

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Solar water heating	£4,000 - £6,000	£78
2. Solar photovoltaic panels	£3,500 - £5,500	£488

Help paying for energy improvements

You might be able to get a grant from the <u>Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme)</u>. This will help you buy a more efficient, low carbon heating system for this property.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Ronnie Watson
Telephone	07925226876
Email	ronnie@eassni.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	ECMK	
Assessor's ID	ECMK302219	
Telephone	0333 123 1418	
Email	info@ecmk.co.uk	

About this assessment

Assessor's declaration	No related party
Date of assessment	9 September 2024
Date of certificate	10 September 2024
Type of assessment	RdSAP