

Energy performance certificate (EPC)

23 Linn Road LARNE BT40 2BS	Energy rating E	Valid until: 10 February 2036
		Certificate number: 2904-1546-1102-0492-8806


Property type End-terrace house

Total floor area 75 square metres

Energy rating and score

This property's energy rating is E. It has the potential to be B.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in Northern Ireland:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Roof	Pitched, 100 mm loft insulation	Average
Window	Single glazed	Very poor
Main heating	Boiler and radiators, oil	Average

Feature	Description	Rating
Main heating control	Programmer and room thermostat	Average
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Below average lighting efficiency	Poor
Floor	Solid, no insulation (assumed)	N/A
Air tightness	(not tested)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 323 kilowatt hours per square metre (kWh/m²).

► [About primary energy use](#)

Smart meters

This property had **no smart meters** when it was assessed.

Smart meters help you understand your energy use and how you could save money. They may help you access better energy deals.

[Find out how to get a smart meter \(https://www.smartenergygb.org/\)](https://www.smartenergygb.org/)

How this affects your energy bills

An average household would need to spend **£1,849 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £930 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2026** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 11,981 kWh per year for heating
- 4,039 kWh per year for hot water

Impact on the environment

This property's environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO ₂
--------------------------------------	-----------------------------

This property produces	5.8 tonnes of CO ₂
-------------------------------	-------------------------------

This property's potential production	2.2 tonnes of CO ₂
---	-------------------------------

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

Step 1: Increase loft insulation to 270 mm

Typical installation cost £900 - £1,200

Typical yearly saving £32

Potential rating after completing step 1 **45 E**

Step 2: Internal wall insulation

Typical installation cost £7,500 - £11,000

Typical yearly saving £364

Potential rating after completing steps 1 and 2 **58 D**

Step 3: Floor insulation (solid floor)

Typical installation cost £5,000 - £10,000

Typical yearly saving £74

Potential rating after completing steps 1 to 3 **60 D**

Step 4: Hot water cylinder insulation

Increase hot water cylinder insulation

Typical installation cost £20 - £40

Typical yearly saving £60

Potential rating after completing steps 1 to 4

62 D

Step 5: Draught proofing

Typical installation cost

£150 - £250

Typical yearly saving

£71

Potential rating after completing steps 1 to 5

63 D

Step 6: Low energy lighting

Typical installation cost

£60 - £70

Typical yearly saving

£27

Potential rating after completing steps 1 to 6

64 D

Step 7: Hot water cylinder thermostat

Typical installation cost

£130 - £180

Typical yearly saving

£97

Potential rating after completing steps 1 to 7

67 D

Step 8: Heating controls (thermostatic radiator valves)

Heating controls (TRVs)

Typical installation cost

£220 - £250

Typical yearly saving

£36

Potential rating after completing steps 1 to 8

68 D

Step 9: Replace boiler with new condensing boiler

Typical installation cost	£2,200 - £3,500
Typical yearly saving	£59
Potential rating after completing steps 1 to 9	70 C

Step 10: Solar water heating

Typical installation cost	£4,000 - £7,000
Typical yearly saving	£26
Potential rating after completing steps 1 to 10	71 C

Step 11: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost	£4,500 - £6,000
Typical yearly saving	£82
Potential rating after completing steps 1 to 11	74 C

Step 12: Solar photovoltaic panels, 2.5 kWp

Typical installation cost	£8,000 - £10,000
Typical yearly saving	£268
Potential rating after completing steps 1 to 12	85 B

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Oliver Clark
Telephone	07951464282
Email	oliverclark105@outlook.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Quidos Limited
Assessor's ID	QUID210128
Telephone	01225 667 570
Email	info@quidos.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	11 February 2026
Date of certificate	11 February 2026
Type of assessment	▶ RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.



[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](#)

OGL

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](#), except where otherwise stated



© Crown copyright (<https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/>)

